

No.05/HRB/RCC/DFO/HGFS/2022.

To

Director General of Police &  
Director General,  
Karnataka Fire & Emergency Services,  
Bangalore - 560042.

Office of the  
District Fire Officer  
High Ground Fire Station  
Bangalore-560 009.  
Dated: 21-11-2022

Sir,

**Sub:** Renewal of Clearance Certificate for High Rise Educational Building constructed and occupied at "A.H. Memorial Educational Trust", CA Cite No. 7P1A, NGEF Layout East, Kasturi Nagar, Bengaluru - inspection report submitted.

- Ref:**
- 1) Chief Office-NOC No. GBC (1) 88/2011 dated: 17-10-2011.
  - 2) Clearance Certificate No. GBC (1) 88/2011 dated: 29-10-2015.
  - 3) Renewal Clearance Certificate No. GBC (1) 88/2011 dated: 19-11-2018.
  - 4) Chief Office Memo No. GBC (1) 88/2011 (KSFES/CC/531/2022) dated: 16-09-2022.

<<<>>>

With reference to the subject cited (1) above, I write to submit that the No Objection Certificate was issued for the construction of High Rise Educational building by "A.H Memorial Educational Trust" comprising of Basement, Ground and 6 Upper floors at CA Cite No.7P1A, NGEF Layout East, Kasturi Nagar, Bengaluru.

As per reference cited (2) above, Clearance Certificate was issued for same.

As per reference cited (3) above, Renewal Clearance Certificate was issued for same.

Now the Applicant in his letter has requested the department to issue Renewal Clearance Certificate for the same.




15	Training	: 40% of the occupants/employees should be got trained in fire prevention & firefighting at the R.A. Mundkur Fire and Emergency Services Academy, Bannerghatta Road, Bangalore – 560 029, within 6 months from the date of occupation of the building. For this purpose before approaching the department for final clearance certificate, the applicant should give an undertaking in the form of an affidavit regarding the maintenance of the fire prevention and firefighting measures suggested above and arranging training of 40% of the Occupants in fire prevention and fire fighting within 6 months from the date of issue of the clearance certificate.	To be attended within 6 months from the occupancy.	In all 03 employees have undergone 30 days training in fire prevention & firefighting at R.A. Mundkur Fire & Emergency Services Academy, Bangalore and the certificates are enclosed. Thus, the requirement is complied with.
----	----------	---	--	---

From the above details it is clear that the **“A.H Memorial Educational Trust”** have been provided and maintained all the required fire prevention, fire fighting and evacuation measures as per NBC Part-III & IV and local zoning regulations at existing High Rise Educational Building comprising of Basement, Ground & 6 Upper floors constructed & occupied at **“A.H Memorial Educational Trust”**, CA Cite No.7P1A, NGEF Layout East, Kasturi Nagar, Bangalore. Hence herewith recommended to renew the clearance certificate for above said Educational Building.

*Submitted for your kind perusal and necessary action.*

Yours Faithfully,

  
 District Fire Officer  
 High Ground Fire Station  
 Sheshadri Road,  
 Bangalore - 560 009.